



QR of Manual

[www.adfweb.com/download/
filefold/MN67507_ENG.pdf](http://www.adfweb.com/download/filefold/MN67507_ENG.pdf)



QR of Box-Sheet

[www.adfweb.com/download/
filefold/BS67507-B2_ENG.pdf](http://www.adfweb.com/download/filefold/BS67507-B2_ENG.pdf)



QR of Software

[www.adfweb.com/download/
filefold/SW67507.zip](http://www.adfweb.com/download/filefold/SW67507.zip)

HD67507-B2

BOX SHEET

**Modbus TCP Slave / Modbus Master
Converter**

Box Sheet for Order code: HD67507-B2
Document code: BS67507-B2
V3.001



ADFweb.com srl

Strada Nuova, 17, IT-31010 Mareno di Piave, Treviso - Italy

www.ADFweb.com

CONNECTION SCHEME

Order code: HD67507-B2



Connector 4:
Port RS232 (D-SUB9-Male)
(Isolated Port)

PIN2 = RX
PIN3 = TX
PIN5 = GND* (to Isolated Ground)

Used for:

- Programmation Port
- Modbus on RS232

To connect the device to the COM port of a PC in order to set it you have to use the programming cable AC34107 or a cable made as showed here:




Led1:
Green
Device state

Led2:
Yellow
CAN comm.

Led4:
Yellow
Ethernet comm.

Led5:
Yellow
Not used

Connector1:
Power Supply port
0V = Ground
+V = Positive wire
V AC: min 8V ; max 24V
V DC: min 12V ; max 35V



Dip-Switch A:
-Dip1 - Functioning Mode
= Normal = Boot

Dip-Switch B:
-Dip1 - RS485 Termination Resistor
= Open = 120 Ohm

Connector3:
RS485 (Isolated port)
S = Shield* (to Isolated Ground)
B = Negative wire
A = Positive wire

Connector5:
Ethernet Port (RJ45 Plug)

Led3:
Green
Ethernet Link



Order code: HD67507-B2